APPENDIX - XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 17

Dated: 15.01.2026

It is certified that an inspection team headed by Er. Brij Bihari Paswan, Assistant Engineer

(Name of Officers with designation) from PHED, Bettiah (Ram nagar)

(Name of Department/ Office) inspected the Sauhardh International School, Harinagar

(Name & Address of the school) on 15.01.2026 (date of inspection) and found that the Sauhardh International School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One year

Signature with Seal: 15/01/26 सहायक अभियंता

Name : Brij. Bihari Paswan

Designation : Assistant Engineer

Name & Address of the Office / Department : PHED, Bettiah

To

Sauhardh International School

Bikrapur - Harinagar Road, Harinagar

West Champaran, Bihar - 845103

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Aditya Kumar Gupta
Principal
Sauhardh International School
Reg. No.-20310142022122115234
UDise Code-10011212011
Harinagar-845103

Ranjeer Kumar
Manager
Sauhardh International School
Reg. No.-20310142022122115234
UDise Code-10011212011
Harinagar-845103

Scanned with OKEN Scanner

District Level Water Testing Laboratory P.H.Division, Bettiah

PUBLIC HEALTH DIVISION, BETTIAH

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON 12/01/2026 BY Mr. Sameer Ra... & RECEIVED IN THE LABORATORY ON 12/01/2026

Sl NO	PARTICULARS OF THE SAMPLE				PARAMETERS EXAMINED (VALUE IN Mg/L except pH. Otherwise Mentioned)														
	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkanity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Flouride	T.D.S	Arsenic	Bacteriological test
1	Ram Nagar	Nagar Parchayat	Harinagar (Bitaspur-Harinagar Road)	Sauhardh International School	1.0	7.3	378	150	158	36	12	23	15	0.2	0.0	0.3	252	N.T	Neg
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5 8.5		200 600	200 600	75 200	30 100	250 1000	200 400	1.0 NR	45 NR	1 1.5	500 2000	0.01 NR	+VE VE

Remarks- Analysed parameters of above samples is within permissible limit.

Aditya Kumar Gupta
Principal
Sauhardh International School
Reg. No.-20310142022122115234
UDise Code-10011212011
Harinagar-845103

Ranjeet Kumar
Manager
Sauhardh International School
Reg. No.-20310142022122115234
UDise Code-10011212011
Harinagar-845103

Signature of Chemist
CHEMIST
DLWTL
P.H. Division, Bettiah.